CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1574:174 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561

Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Model 472462 combination fire and burglary alarm control unit. Automatic, manual, local,

remote station (PPU), central station (PPU), proprietary station (PPU), waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description

and operational considerations. System components:

472462 Control unit

SAFOC200 Sub-assembly Circuit Board

COM-UL Enclosure 443216 or 472404 Transformer

RATING: 120 VAC, 18 VAC, Transformer and 12 VDC battery back-up

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a combination fire and burglary alarm control units for use with the separately listed

compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per

NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7165-0085:190

XLF: 7165-0078:197

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 23, 2004 Listing Expires June 30, 2005

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager